

HYDRO PRESSURE TEST

TC No.: HPT/A4/A90/RQ/174/25	Model No.: KFARQ-4-90%	Date: 26-09-2025
Type and Capacity of Extinguisher	: KFARQ-4-90%-Kanex ABC Dry Powder Fire Extinguisher Cap. 4 Kg.	
Batch Number	: KFARQ90%4 174/25	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 17301 To 17400 And 17305A	
Month of Manufacturing	: Sep/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 17305A and removed from the Lot/Batch							
17301	Pass	17302	Pass	17303	Pass	17304	Pass
17305	Pass	17306	Pass	17307	Pass	17308	Pass
17309	Pass	17310	Pass	17311	Pass	17312	Pass
17313	Pass	17314	Pass	17315	Pass	17316	Pass
17317	Pass	17318	Pass	17319	Pass	17320	Pass
17321	Pass	17322	Pass	17323	Pass	17324	Pass
17325	Pass	17326	Pass	17327	Pass	17328	Pass
17329	Pass	17330	Pass	17331	Pass	17332	Pass
17333	Pass	17334	Pass	17335	Pass	17336	Pass
17337	Pass	17338	Pass	17339	Pass	17340	Pass
17341	Pass	17342	Pass	17343	Pass	17344	Pass
17345	Pass	17346	Pass	17347	Pass	17348	Pass
17349	Pass	17350	Pass	17351	Pass	17352	Pass
17353	Pass	17354	Pass	17355	Pass	17356	Pass
17357	Pass	17358	Pass	17359	Pass	17360	Pass
17361	Pass	17362	Pass	17363	Pass	17364	Pass
17365	Pass	17366	Pass	17367	Pass	17368	Pass
17369	Pass	17370	Pass	17371	Pass	17372	Pass
17373	Pass	17374	Pass	17375	Pass	17376	Pass
17377	Pass	17378	Pass	17379	Pass	17380	Pass
17381	Pass	17382	Pass	17383	Pass	17384	Pass
17385	Pass	17386	Pass	17387	Pass	17388	Pass
17389	Pass	17390	Pass	17391	Pass	17392	Pass
17393	Pass	17394	Pass	17395	Pass	17396	Pass
17397	Pass	17398	Pass	17399	Pass	17400	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory