

HYDRO PRESSURE TEST

TC No.: HPT/A4/A90/RQ/175/25	Model No.: KFARQ-4-90%	Date: 04-10-2025
Type and Capacity of Extinguisher	: KFARQ-4-90%-Kanex ABC Dry Powder Fire Extinguisher Cap. 4 Kg.	
Batch Number	: KFARQ90%4 175/25	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 17401 To 17500 And 17405A	
Month of Manufacturing	: Oct/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 17405A and removed from the Lot/Batch							
17401	Pass	17402	Pass	17403	Pass	17404	Pass
17405	Pass	17406	Pass	17407	Pass	17408	Pass
17409	Pass	17410	Pass	17411	Pass	17412	Pass
17413	Pass	17414	Pass	17415	Pass	17416	Pass
17417	Pass	17418	Pass	17419	Pass	17420	Pass
17421	Pass	17422	Pass	17423	Pass	17424	Pass
17425	Pass	17426	Pass	17427	Pass	17428	Pass
17429	Pass	17430	Pass	17431	Pass	17432	Pass
17433	Pass	17434	Pass	17435	Pass	17436	Pass
17437	Pass	17438	Pass	17439	Pass	17440	Pass
17441	Pass	17442	Pass	17443	Pass	17444	Pass
17445	Pass	17446	Pass	17447	Pass	17448	Pass
17449	Pass	17450	Pass	17451	Pass	17452	Pass
17453	Pass	17454	Pass	17455	Pass	17456	Pass
17457	Pass	17458	Pass	17459	Pass	17460	Pass
17461	Pass	17462	Pass	17463	Pass	17464	Pass
17465	Pass	17466	Pass	17467	Pass	17468	Pass
17469	Pass	17470	Pass	17471	Pass	17472	Pass
17473	Pass	17474	Pass	17475	Pass	17476	Pass
17477	Pass	17478	Pass	17479	Pass	17480	Pass
17481	Pass	17482	Pass	17483	Pass	17484	Pass
17485	Pass	17486	Pass	17487	Pass	17488	Pass
17489	Pass	17490	Pass	17491	Pass	17492	Pass
17493	Pass	17494	Pass	17495	Pass	17496	Pass
17497	Pass	17498	Pass	17499	Pass	17500	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory