

HYDRO PRESSURE TEST

TC No.: HPT/A6/A50/RQ/353/25	Model No.: KFARQ-6-50%	Date: 18-12-2025
Type and Capacity of Extinguisher	: KFARQ-6-50%-Kanex ABC Dry Powder Fire Extinguisher Cap. 6 Kg.	
Batch Number	: KFARQ50%6 353/25	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 35201 To 35300 And 35205A	
Month of Manufacturing	: Dec/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 35205A and removed from the Lot/Batch							
35201	Pass	35202	Pass	35203	Pass	35204	Pass
35205	Pass	35206	Pass	35207	Pass	35208	Pass
35209	Pass	35210	Pass	35211	Pass	35212	Pass
35213	Pass	35214	Pass	35215	Pass	35216	Pass
35217	Pass	35218	Pass	35219	Pass	35220	Pass
35221	Pass	35222	Pass	35223	Pass	35224	Pass
35225	Pass	35226	Pass	35227	Pass	35228	Pass
35229	Pass	35230	Pass	35231	Pass	35232	Pass
35233	Pass	35234	Pass	35235	Pass	35236	Pass
35237	Pass	35238	Pass	35239	Pass	35240	Pass
35241	Pass	35242	Pass	35243	Pass	35244	Pass
35245	Pass	35246	Pass	35247	Pass	35248	Pass
35249	Pass	35250	Pass	35251	Pass	35252	Pass
35253	Pass	35254	Pass	35255	Pass	35256	Pass
35257	Pass	35258	Pass	35259	Pass	35260	Pass
35261	Pass	35262	Pass	35263	Pass	35264	Pass
35265	Pass	35266	Pass	35267	Pass	35268	Pass
35269	Pass	35270	Pass	35271	Pass	35272	Pass
35273	Pass	35274	Pass	35275	Pass	35276	Pass
35277	Pass	35278	Pass	35279	Pass	35280	Pass
35281	Pass	35282	Pass	35283	Pass	35284	Pass
35285	Pass	35286	Pass	35287	Pass	35288	Pass
35289	Pass	35290	Pass	35291	Pass	35292	Pass
35293	Pass	35294	Pass	35295	Pass	35296	Pass
35297	Pass	35298	Pass	35299	Pass	35300	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory