

HYDRO PRESSURE TEST

TC No.: HPT/A6/A50/RQ/354/25	Model No.: KFARQ-6-50%	Date: 18-12-2025
Type and Capacity of Extinguisher	: KFARQ-6-50%-Kanex ABC Dry Powder Fire Extinguisher Cap. 6 Kg.	
Batch Number	: KFARQ50%6 354/25	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 35301 To 35400 And 35305A	
Month of Manufacturing	: Dec/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 35305A and removed from the Lot/Batch							
35301	Pass	35302	Pass	35303	Pass	35304	Pass
35305	Pass	35306	Pass	35307	Pass	35308	Pass
35309	Pass	35310	Pass	35311	Pass	35312	Pass
35313	Pass	35314	Pass	35315	Pass	35316	Pass
35317	Pass	35318	Pass	35319	Pass	35320	Pass
35321	Pass	35322	Pass	35323	Pass	35324	Pass
35325	Pass	35326	Pass	35327	Pass	35328	Pass
35329	Pass	35330	Pass	35331	Pass	35332	Pass
35333	Pass	35334	Pass	35335	Pass	35336	Pass
35337	Pass	35338	Pass	35339	Pass	35340	Pass
35341	Pass	35342	Pass	35343	Pass	35344	Pass
35345	Pass	35346	Pass	35347	Pass	35348	Pass
35349	Pass	35350	Pass	35351	Pass	35352	Pass
35353	Pass	35354	Pass	35355	Pass	35356	Pass
35357	Pass	35358	Pass	35359	Pass	35360	Pass
35361	Pass	35362	Pass	35363	Pass	35364	Pass
35365	Pass	35366	Pass	35367	Pass	35368	Pass
35369	Pass	35370	Pass	35371	Pass	35372	Pass
35373	Pass	35374	Pass	35375	Pass	35376	Pass
35377	Pass	35378	Pass	35379	Pass	35380	Pass
35381	Pass	35382	Pass	35383	Pass	35384	Pass
35385	Pass	35386	Pass	35387	Pass	35388	Pass
35389	Pass	35390	Pass	35391	Pass	35392	Pass
35393	Pass	35394	Pass	35395	Pass	35396	Pass
35397	Pass	35398	Pass	35399	Pass	35400	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.


 SIHOR
 (GUJARAT)

Authorized Signatory