

HYDRO PRESSURE TEST

TC No.: HPT/MOD5/CA/RQ/073/25	Model No.: KMCRQ-5	Date: 02-12-2025
Type and Capacity of Extinguisher	: KMCRQ-5-Kanex Clean Agent Modular HFC Based Fire Extinguisher Cap. 5 Kg.	
Batch Number	: KMCRQ5 073/25	
Batch Quantity	: 50.00 Nos.	
Serial Numbers	: 03601 To 3650	
Month of Manufacturing	: Dec/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 03601 To 3650 and removed from the Lot/Batch							
3601	Pass	3602	Pass	3603	Pass	3604	Pass
3605	Pass	3606	Pass	3607	Pass	3608	Pass
3609	Pass	3610	Pass	3611	Pass	3612	Pass
3613	Pass	3614	Pass	3615	Pass	3616	Pass
3617	Pass	3618	Pass	3619	Pass	3620	Pass
3621	Pass	3622	Pass	3623	Pass	3624	Pass
3625	Pass	3626	Pass	3627	Pass	3628	Pass
3629	Pass	3630	Pass	3631	Pass	3632	Pass
3633	Pass	3634	Pass	3635	Pass	3636	Pass
3637	Pass	3638	Pass	3639	Pass	3640	Pass
3641	Pass	3642	Pass	3643	Pass	3644	Pass
3645	Pass	3646	Pass	3647	Pass	3648	Pass
3649	Pass	3650	Pass				

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory