

HYDRO PRESSURE TEST

TC No.: HPT/MA6/A40/RQ/232/25	Model No.: MARQ-6-50%	Date: 22-07-2025
Type and Capacity of Extinguisher	: MARQ-6-50%-Kanex ABC Dry Powder Fire Extinguisher Cap. 6 Kg.	
Batch Number	: MARQ50%6 232/25	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 23101 To 23200 And 23105A	
Month of Manufacturing	: Jul/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 23105A and removed from the Lot/Batch							
23101	Pass	23102	Pass	23103	Pass	23104	Pass
23105	Pass	23106	Pass	23107	Pass	23108	Pass
23109	Pass	23110	Pass	23111	Pass	23112	Pass
23113	Pass	23114	Pass	23115	Pass	23116	Pass
23117	Pass	23118	Pass	23119	Pass	23120	Pass
23121	Pass	23122	Pass	23123	Pass	23124	Pass
23125	Pass	23126	Pass	23127	Pass	23128	Pass
23129	Pass	23130	Pass	23131	Pass	23132	Pass
23133	Pass	23134	Pass	23135	Pass	23136	Pass
23137	Pass	23138	Pass	23139	Pass	23140	Pass
23141	Pass	23142	Pass	23143	Pass	23144	Pass
23145	Pass	23146	Pass	23147	Pass	23148	Pass
23149	Pass	23150	Pass	23151	Pass	23152	Pass
23153	Pass	23154	Pass	23155	Pass	23156	Pass
23157	Pass	23158	Pass	23159	Pass	23160	Pass
23161	Pass	23162	Pass	23163	Pass	23164	Pass
23165	Pass	23166	Pass	23167	Pass	23168	Pass
23169	Pass	23170	Pass	23171	Pass	23172	Pass
23173	Pass	23174	Pass	23175	Pass	23176	Pass
23177	Pass	23178	Pass	23179	Pass	23180	Pass
23181	Pass	23182	Pass	23183	Pass	23184	Pass
23185	Pass	23186	Pass	23187	Pass	23188	Pass
23189	Pass	23190	Pass	23191	Pass	23192	Pass
23193	Pass	23194	Pass	23195	Pass	23196	Pass
23197	Pass	23198	Pass	23199	Pass	23200	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory