

HYDRO PRESSURE TEST

TC No.: HPT/A6/A90/RQ/295/25	Model No.: KFARQ-6-90%	Date: 16-12-2025
Type and Capacity of Extinguisher	: KFARQ-6-90%-Kanex ABC Dry Powder Fire Extinguisher Cap. 6 Kg.	
Batch Number	: KFARQ90%6 295/25	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 29401 To 29500 And 29405A	
Month of Manufacturing	: Dec/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 29405A and removed from the Lot/Batch							
29401	Pass	29402	Pass	29403	Pass	29404	Pass
29405	Pass	29406	Pass	29407	Pass	29408	Pass
29409	Pass	29410	Pass	29411	Pass	29412	Pass
29413	Pass	29414	Pass	29415	Pass	29416	Pass
29417	Pass	29418	Pass	29419	Pass	29420	Pass
29421	Pass	29422	Pass	29423	Pass	29424	Pass
29425	Pass	29426	Pass	29427	Pass	29428	Pass
29429	Pass	29430	Pass	29431	Pass	29432	Pass
29433	Pass	29434	Pass	29435	Pass	29436	Pass
29437	Pass	29438	Pass	29439	Pass	29440	Pass
29441	Pass	29442	Pass	29443	Pass	29444	Pass
29445	Pass	29446	Pass	29447	Pass	29448	Pass
29449	Pass	29450	Pass	29451	Pass	29452	Pass
29453	Pass	29454	Pass	29455	Pass	29456	Pass
29457	Pass	29458	Pass	29459	Pass	29460	Pass
29461	Pass	29462	Pass	29463	Pass	29464	Pass
29465	Pass	29466	Pass	29467	Pass	29468	Pass
29469	Pass	29470	Pass	29471	Pass	29472	Pass
29473	Pass	29474	Pass	29475	Pass	29476	Pass
29477	Pass	29478	Pass	29479	Pass	29480	Pass
29481	Pass	29482	Pass	29483	Pass	29484	Pass
29485	Pass	29486	Pass	29487	Pass	29488	Pass
29489	Pass	29490	Pass	29491	Pass	29492	Pass
29493	Pass	29494	Pass	29495	Pass	29496	Pass
29497	Pass	29498	Pass	29499	Pass	29500	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory