

HYDRO PRESSURE TEST

TC No.: HPT/F9/SP/RQ/049/25	Model No.: KFMSRQ-9	Date: 27-07-2025
Type and Capacity of Extinguisher	: KFMSRQ-9-Kanex M Foam SP Fire Extinguisher Cap. 9 Ltr.	
Batch Number	: KFMSRQ9 049/25	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 04801 To 4900 And 4805A	
Month of Manufacturing	: Jul/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 4805A and removed from the Lot/Batch							
4801	Pass	4802	Pass	4803	Pass	4804	Pass
4805	Pass	4806	Pass	4807	Pass	4808	Pass
4809	Pass	4810	Pass	4811	Pass	4812	Pass
4813	Pass	4814	Pass	4815	Pass	4816	Pass
4817	Pass	4818	Pass	4819	Pass	4820	Pass
4821	Pass	4822	Pass	4823	Pass	4824	Pass
4825	Pass	4826	Pass	4827	Pass	4828	Pass
4829	Pass	4830	Pass	4831	Pass	4832	Pass
4833	Pass	4834	Pass	4835	Pass	4836	Pass
4837	Pass	4838	Pass	4839	Pass	4840	Pass
4841	Pass	4842	Pass	4843	Pass	4844	Pass
4845	Pass	4846	Pass	4847	Pass	4848	Pass
4849	Pass	4850	Pass	4851	Pass	4852	Pass
4853	Pass	4854	Pass	4855	Pass	4856	Pass
4857	Pass	4858	Pass	4859	Pass	4860	Pass
4861	Pass	4862	Pass	4863	Pass	4864	Pass
4865	Pass	4866	Pass	4867	Pass	4868	Pass
4869	Pass	4870	Pass	4871	Pass	4872	Pass
4873	Pass	4874	Pass	4875	Pass	4876	Pass
4877	Pass	4878	Pass	4879	Pass	4880	Pass
4881	Pass	4882	Pass	4883	Pass	4884	Pass
4885	Pass	4886	Pass	4887	Pass	4888	Pass
4889	Pass	4890	Pass	4891	Pass	4892	Pass
4893	Pass	4894	Pass	4895	Pass	4896	Pass
4897	Pass	4898	Pass	4899	Pass	4900	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory