

HYDRO PRESSURE TEST

TC No.: HPT/F9/SP/RQ/052/25	Model No.: KFMSRQ-9	Date: 14-08-2025
Type and Capacity of Extinguisher	: KFMSRQ-9-Kanex M Foam SP Fire Extinguisher Cap. 9 Ltr.	
Batch Number	: KFMSRQ9 052/25	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 05101 To 5200 And 5105A	
Month of Manufacturing	: Aug/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 5105A and removed from the Lot/Batch							
5101	Pass	5102	Pass	5103	Pass	5104	Pass
5105	Pass	5106	Pass	5107	Pass	5108	Pass
5109	Pass	5110	Pass	5111	Pass	5112	Pass
5113	Pass	5114	Pass	5115	Pass	5116	Pass
5117	Pass	5118	Pass	5119	Pass	5120	Pass
5121	Pass	5122	Pass	5123	Pass	5124	Pass
5125	Pass	5126	Pass	5127	Pass	5128	Pass
5129	Pass	5130	Pass	5131	Pass	5132	Pass
5133	Pass	5134	Pass	5135	Pass	5136	Pass
5137	Pass	5138	Pass	5139	Pass	5140	Pass
5141	Pass	5142	Pass	5143	Pass	5144	Pass
5145	Pass	5146	Pass	5147	Pass	5148	Pass
5149	Pass	5150	Pass	5151	Pass	5152	Pass
5153	Pass	5154	Pass	5155	Pass	5156	Pass
5157	Pass	5158	Pass	5159	Pass	5160	Pass
5161	Pass	5162	Pass	5163	Pass	5164	Pass
5165	Pass	5166	Pass	5167	Pass	5168	Pass
5169	Pass	5170	Pass	5171	Pass	5172	Pass
5173	Pass	5174	Pass	5175	Pass	5176	Pass
5177	Pass	5178	Pass	5179	Pass	5180	Pass
5181	Pass	5182	Pass	5183	Pass	5184	Pass
5185	Pass	5186	Pass	5187	Pass	5188	Pass
5189	Pass	5190	Pass	5191	Pass	5192	Pass
5193	Pass	5194	Pass	5195	Pass	5196	Pass
5197	Pass	5198	Pass	5199	Pass	5200	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory