

HELIUM LEAK DETECTION TEST

TC No.: HLD/A9/K/HQ/025/24

Model No.: KFKHQ-9

Date: 13-10-2024

Type and Capacity of Extinguisher : KFKHQ-9-Kanex F Class Kitchen Fire Extinguisher Cap. 9 Ltr.

Batch Number : KFKHQ9 025/24

Batch Quantity : 10 Nos.

Serial Numbers : 00241 To 250

Month of Manufacturing : Oct/24

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
241	Pass	242	Pass	243	Pass	244	Pass
245	Pass	246	Pass	247	Pass	248	Pass
249	Pass	250	Pass				

Remarks: This is to certify that the above mentioned Fire Extinguishers has been tested on Mass Spectrometer Helium Leak Detector, with test pressure of 1 mbar and desired leak rate of 1×10^{-6} mbar.l/sec and no any cylinders shows leakage beyond this limit.



Authorized Signatory