



# Warranty Certificate

Date: 13-01-2026**Manufacturer:** Kanex Fire Solutions Limited.**Customer Name:** Cease Fire Extinguisher & Systems India Pvt. Ltd.**Warranty Start Date:** 13-01-2026**Warranty End Date:** 12-01-2027.

This is to certify that the below extinguishers are warranted for a period of **1** year from the date of supply against any of Manufacturing/Quality defects.

**NOTE – IF TAMPER SEAL IS NOT INTACT, THE WARRANTY SHALL BE CONSIDERED VOID.**

| Sr.No. | Type & Capacity of Extinguishers                                     | Quantity | Sr. Nos.            |
|--------|----------------------------------------------------------------------|----------|---------------------|
| 1      | KCARQ-4-Kanex Clean Agent HFC Based Fire Extinguisher Cap. 4 Kg.     | 2        | As Per Annexure – I |
| 2      | KFCRQ-4.5-Kanex CO2 High Pressure Fire Extinguisher Cap. 4.5 Kg.     | 5        | As Per Annexure – I |
| 3      | KFMRQ-45-Kanex M Foam Trolley Mounted Fire Extinguisher Cap. 45 Ltr. | 2        | As Per Annexure – I |

Also certify that, all the Fire extinguishers supplied against Invoice No. **25-26/M/000574 Dated: 13-01-2026 P.O.No. CF/FT/CO/1512** are hydraulically tested 100% at 35 bar except CO2 and randomly tested for performance test. All the extinguishers confirms to IS 15683:2018 (Portable) or IS 16018:2012 (Mobile) requirements.

Note : If applicable CO2 Cylinders are PESO approved & HPT tested at 225 bar by Cylinder Manufacturer.

**Authorized Signatory**