

HYDRO PRESSURE TEST

TC No.: HPT/A2/A90/RQ/096/25	Model No.: KFARQ-2-90%	Date: 21-11-2025
Type and Capacity of Extinguisher	: KFARQ-2-90%-Kanex ABC Dry Powder Fire Extinguisher Cap. 2 Kg.	
Batch Number	: KFARQ90%2 096/25	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 09501 To 9600 And 9505A	
Month of Manufacturing	: Nov/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 9505A and removed from the Lot/Batch							
9501	Pass	9502	Pass	9503	Pass	9504	Pass
9505	Pass	9506	Pass	9507	Pass	9508	Pass
9509	Pass	9510	Pass	9511	Pass	9512	Pass
9513	Pass	9514	Pass	9515	Pass	9516	Pass
9517	Pass	9518	Pass	9519	Pass	9520	Pass
9521	Pass	9522	Pass	9523	Pass	9524	Pass
9525	Pass	9526	Pass	9527	Pass	9528	Pass
9529	Pass	9530	Pass	9531	Pass	9532	Pass
9533	Pass	9534	Pass	9535	Pass	9536	Pass
9537	Pass	9538	Pass	9539	Pass	9540	Pass
9541	Pass	9542	Pass	9543	Pass	9544	Pass
9545	Pass	9546	Pass	9547	Pass	9548	Pass
9549	Pass	9550	Pass	9551	Pass	9552	Pass
9553	Pass	9554	Pass	9555	Pass	9556	Pass
9557	Pass	9558	Pass	9559	Pass	9560	Pass
9561	Pass	9562	Pass	9563	Pass	9564	Pass
9565	Pass	9566	Pass	9567	Pass	9568	Pass
9569	Pass	9570	Pass	9571	Pass	9572	Pass
9573	Pass	9574	Pass	9575	Pass	9576	Pass
9577	Pass	9578	Pass	9579	Pass	9580	Pass
9581	Pass	9582	Pass	9583	Pass	9584	Pass
9585	Pass	9586	Pass	9587	Pass	9588	Pass
9589	Pass	9590	Pass	9591	Pass	9592	Pass
9593	Pass	9594	Pass	9595	Pass	9596	Pass
9597	Pass	9598	Pass	9599	Pass	9600	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory