

HYDRO PRESSURE TEST

TC No.: HPT/A6/A90/RQ/294/25	Model No.: KFARQ-6-90%	Date: 16-12-2025
Type and Capacity of Extinguisher	: KFARQ-6-90%-Kanex ABC Dry Powder Fire Extinguisher Cap. 6 Kg.	
Batch Number	: KFARQ90%6 294/25	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 29301 To 29400 And 29305A	
Month of Manufacturing	: Dec/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 29305A and removed from the Lot/Batch							
29301	Pass	29302	Pass	29303	Pass	29304	Pass
29305	Pass	29306	Pass	29307	Pass	29308	Pass
29309	Pass	29310	Pass	29311	Pass	29312	Pass
29313	Pass	29314	Pass	29315	Pass	29316	Pass
29317	Pass	29318	Pass	29319	Pass	29320	Pass
29321	Pass	29322	Pass	29323	Pass	29324	Pass
29325	Pass	29326	Pass	29327	Pass	29328	Pass
29329	Pass	29330	Pass	29331	Pass	29332	Pass
29333	Pass	29334	Pass	29335	Pass	29336	Pass
29337	Pass	29338	Pass	29339	Pass	29340	Pass
29341	Pass	29342	Pass	29343	Pass	29344	Pass
29345	Pass	29346	Pass	29347	Pass	29348	Pass
29349	Pass	29350	Pass	29351	Pass	29352	Pass
29353	Pass	29354	Pass	29355	Pass	29356	Pass
29357	Pass	29358	Pass	29359	Pass	29360	Pass
29361	Pass	29362	Pass	29363	Pass	29364	Pass
29365	Pass	29366	Pass	29367	Pass	29368	Pass
29369	Pass	29370	Pass	29371	Pass	29372	Pass
29373	Pass	29374	Pass	29375	Pass	29376	Pass
29377	Pass	29378	Pass	29379	Pass	29380	Pass
29381	Pass	29382	Pass	29383	Pass	29384	Pass
29385	Pass	29386	Pass	29387	Pass	29388	Pass
29389	Pass	29390	Pass	29391	Pass	29392	Pass
29393	Pass	29394	Pass	29395	Pass	29396	Pass
29397	Pass	29398	Pass	29399	Pass	29400	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory