

HYDRO PRESSURE TEST

TC No.: HPT/W45/RQ/001/26	Model No.: KFWRQ-45	Date: 03-01-2026
Type and Capacity of Extinguisher	: KFWRQ-45-Kanex Water Trolley Mounted Fire Extinguisher Cap. 45 Ltr.	
Batch Number	: KFWRQ45 001/26	
Batch Quantity	: 6.00 Nos.	
Serial Numbers	: 00001 To 5 And 5A	
Month of Manufacturing	: Jan/26	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 5A and removed from the Lot/Batch							
1	Pass	2	Pass	3	Pass	4	Pass
5	Pass						

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 Minute and found satisfactory. No any leakage observed.



Authorized Signatory