

HYDRO PRESSURE TEST

TC No.: HPT/A9/K/HQ/026/24	Model No.: KFKHQ-9	Date: 11-10-2024
Type and Capacity of Extinguisher	: KFKHQ-9-Kanex F Class Kitchen Fire Extinguisher Cap. 9 Ltr.	
Batch Number	: KFKHQ9 026/24	
Batch Quantity	: 10.00 Nos.	
Serial Numbers	: 00251 To 260	
Month of Manufacturing	: Oct/24	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 00251 To 260 and removed from the Lot/Batch							
251	Pass	252	Pass	253	Pass	254	Pass
255	Pass	256	Pass	257	Pass	258	Pass
259	Pass	260	Pass				

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory