

HYDRO PRESSURE TEST

TC No.: HPT/MOD5/CA/RQ/002/26	Model No.: KMCRQ-5	Date: 04-01-2026
Type and Capacity of Extinguisher	: KMCRQ-5-Kanex Clean Agent Modular HFC Based Fire Extinguisher Cap. 5 Kg.	
Batch Number	: KMCRQ5 002/26	
Batch Quantity	: 50.00 Nos.	
Serial Numbers	: 00051 To 100	
Month of Manufacturing	: Jan/26	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 00051 To 100 and removed from the Lot/Batch							
51	Pass	52	Pass	53	Pass	54	Pass
55	Pass	56	Pass	57	Pass	58	Pass
59	Pass	60	Pass	61	Pass	62	Pass
63	Pass	64	Pass	65	Pass	66	Pass
67	Pass	68	Pass	69	Pass	70	Pass
71	Pass	72	Pass	73	Pass	74	Pass
75	Pass	76	Pass	77	Pass	78	Pass
79	Pass	80	Pass	81	Pass	82	Pass
83	Pass	84	Pass	85	Pass	86	Pass
87	Pass	88	Pass	89	Pass	90	Pass
91	Pass	92	Pass	93	Pass	94	Pass
95	Pass	96	Pass	97	Pass	98	Pass
99	Pass	100	Pass				

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory