

HYDRO PRESSURE TEST

TC No.: HPT/A4/A50/RQ/099/25	Model No.: KFARQ-4-50%	Date: 18-12-2025
Type and Capacity of Extinguisher	: KFARQ-4-50%-Kanex ABC Dry Powder Fire Extinguisher Cap. 4 Kg.	
Batch Number	: KFARQ50%4 099/25	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 09801 To 9900 And 9805A	
Month of Manufacturing	: Dec/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 9805A and removed from the Lot/Batch							
9801	Pass	9802	Pass	9803	Pass	9804	Pass
9805	Pass	9806	Pass	9807	Pass	9808	Pass
9809	Pass	9810	Pass	9811	Pass	9812	Pass
9813	Pass	9814	Pass	9815	Pass	9816	Pass
9817	Pass	9818	Pass	9819	Pass	9820	Pass
9821	Pass	9822	Pass	9823	Pass	9824	Pass
9825	Pass	9826	Pass	9827	Pass	9828	Pass
9829	Pass	9830	Pass	9831	Pass	9832	Pass
9833	Pass	9834	Pass	9835	Pass	9836	Pass
9837	Pass	9838	Pass	9839	Pass	9840	Pass
9841	Pass	9842	Pass	9843	Pass	9844	Pass
9845	Pass	9846	Pass	9847	Pass	9848	Pass
9849	Pass	9850	Pass	9851	Pass	9852	Pass
9853	Pass	9854	Pass	9855	Pass	9856	Pass
9857	Pass	9858	Pass	9859	Pass	9860	Pass
9861	Pass	9862	Pass	9863	Pass	9864	Pass
9865	Pass	9866	Pass	9867	Pass	9868	Pass
9869	Pass	9870	Pass	9871	Pass	9872	Pass
9873	Pass	9874	Pass	9875	Pass	9876	Pass
9877	Pass	9878	Pass	9879	Pass	9880	Pass
9881	Pass	9882	Pass	9883	Pass	9884	Pass
9885	Pass	9886	Pass	9887	Pass	9888	Pass
9889	Pass	9890	Pass	9891	Pass	9892	Pass
9893	Pass	9894	Pass	9895	Pass	9896	Pass
9897	Pass	9898	Pass	9899	Pass	9900	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory