

HYDRO PRESSURE TEST

TC No.: HPT/MOD2/CA/RQ/005/25

Model No.: KMCRQ-2

Date: 10-07-2025

Type and Capacity of Extinguisher : KMCRQ-2-Kanex Clean Agent Modular HFC Based Fire Extinguisher Cap. 2 Kg.

Batch Number : KMCRQ2 005/25

Batch Quantity : 20.00 Nos.

Serial Numbers : 00081 To 100

Month of Manufacturing : Jul/25

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 00081 To 100 and removed from the Lot/Batch							
81	Pass	82	Pass	83	Pass	84	Pass
85	Pass	86	Pass	87	Pass	88	Pass
89	Pass	90	Pass	91	Pass	92	Pass
93	Pass	94	Pass	95	Pass	96	Pass
97	Pass	98	Pass	99	Pass	100	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.

**Authorized Signatory**