

HYDRO PRESSURE TEST

TC No.: HPT/A6/A50/RQ/051/26	Model No.: KFARQ-6-50%	Date: 10-02-2026
Type and Capacity of Extinguisher	: KFARQ-6-50%-Kanex ABC Dry Powder Fire Extinguisher Cap. 6 Kg.	
Batch Number	: KFARQ50%6 051/26	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 05001 To 5100 And 5005A	
Month of Manufacturing	: Feb/26	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 5005A and removed from the Lot/Batch							
5001	Pass	5002	Pass	5003	Pass	5004	Pass
5005	Pass	5006	Pass	5007	Pass	5008	Pass
5009	Pass	5010	Pass	5011	Pass	5012	Pass
5013	Pass	5014	Pass	5015	Pass	5016	Pass
5017	Pass	5018	Pass	5019	Pass	5020	Pass
5021	Pass	5022	Pass	5023	Pass	5024	Pass
5025	Pass	5026	Pass	5027	Pass	5028	Pass
5029	Pass	5030	Pass	5031	Pass	5032	Pass
5033	Pass	5034	Pass	5035	Pass	5036	Pass
5037	Pass	5038	Pass	5039	Pass	5040	Pass
5041	Pass	5042	Pass	5043	Pass	5044	Pass
5045	Pass	5046	Pass	5047	Pass	5048	Pass
5049	Pass	5050	Pass	5051	Pass	5052	Pass
5053	Pass	5054	Pass	5055	Pass	5056	Pass
5057	Pass	5058	Pass	5059	Pass	5060	Pass
5061	Pass	5062	Pass	5063	Pass	5064	Pass
5065	Pass	5066	Pass	5067	Pass	5068	Pass
5069	Pass	5070	Pass	5071	Pass	5072	Pass
5073	Pass	5074	Pass	5075	Pass	5076	Pass
5077	Pass	5078	Pass	5079	Pass	5080	Pass
5081	Pass	5082	Pass	5083	Pass	5084	Pass
5085	Pass	5086	Pass	5087	Pass	5088	Pass
5089	Pass	5090	Pass	5091	Pass	5092	Pass
5093	Pass	5094	Pass	5095	Pass	5096	Pass
5097	Pass	5098	Pass	5099	Pass	5100	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory