

HELIUM LEAK DETECTION TEST

TC No.: HLD/A6/K/HQ/014/26	Model No.: KFKHQ-6	Date: 29-01-2026
Type and Capacity of Extinguisher	: KFKHQ-6-Kanex F Class Kitchen Fire Extinguisher Cap. 6 Ltr.	
Batch Number	: KFKHQ6 014/26	
Batch Quantity	: 10 Nos.	
Serial Numbers	: 00131 To 140	
Month of Manufacturing	: Jan/26	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
131	Pass	132	Pass	133	Pass	134	Pass
135	Pass	136	Pass	137	Pass	138	Pass
139	Pass	140	Pass				

Remarks: This is to certify that the above mentioned Fire Extinguishers has been tested on Mass Spectrometer Helium Leak Detector, with test pressure of 1 mbar and desired leak rate of 1×10^{-6} mbar.l/sec and no any cylinders shows leakage beyond this limit.



Authorized Signatory