

HYDRO PRESSURE TEST

TC No.: HPT/MOD10/CA/RQ/180/25	Model No.: KMCRQ-10	Date: 04-12-2025
Type and Capacity of Extinguisher	: KMCRQ-10-Kanex Clean Agent Modular HFC Based Fire Extinguisher Cap. 10 Kg.	
Batch Number	: KMCRQ10 180/25	
Batch Quantity	: 10.00 Nos.	
Serial Numbers	: 01791 To 1800	
Month of Manufacturing	: Dec/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 01791 To 1800 and removed from the Lot/Batch							
1791	Pass	1792	Pass	1793	Pass	1794	Pass
1795	Pass	1796	Pass	1797	Pass	1798	Pass
1799	Pass	1800	Pass				

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory