

HYDRO PRESSURE TEST

TC No.: HPT/MOD5/CA/RQ/018/26	Model No.: KMCRQ-5	Date: 12-02-2026
Type and Capacity of Extinguisher	: KMCRQ-5-Kanex Clean Agent Modular HFC Based Fire Extinguisher Cap. 5 Kg.	
Batch Number	: KMCRQ5 018/26	
Batch Quantity	: 50.00 Nos.	
Serial Numbers	: 00851 To 900	
Month of Manufacturing	: Feb/26	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 00851 To 900 and removed from the Lot/Batch							
851	Pass	852	Pass	853	Pass	854	Pass
855	Pass	856	Pass	857	Pass	858	Pass
859	Pass	860	Pass	861	Pass	862	Pass
863	Pass	864	Pass	865	Pass	866	Pass
867	Pass	868	Pass	869	Pass	870	Pass
871	Pass	872	Pass	873	Pass	874	Pass
875	Pass	876	Pass	877	Pass	878	Pass
879	Pass	880	Pass	881	Pass	882	Pass
883	Pass	884	Pass	885	Pass	886	Pass
887	Pass	888	Pass	889	Pass	890	Pass
891	Pass	892	Pass	893	Pass	894	Pass
895	Pass	896	Pass	897	Pass	898	Pass
899	Pass	900	Pass				

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory