

HYDRO PRESSURE TEST

TC No.: HPT/MOD10/CA/RQ/178/25	Model No.: KMCRQ-10	Date: 02-12-2025
Type and Capacity of Extinguisher	: KMCRQ-10-Kanex Clean Agent Modular HFC Based Fire Extinguisher Cap. 10 Kg.	
Batch Number	: KMCRQ10 178/25	
Batch Quantity	: 10.00 Nos.	
Serial Numbers	: 01771 To 1780	
Month of Manufacturing	: Dec/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 01771 To 1780 and removed from the Lot/Batch							
1771	Pass	1772	Pass	1773	Pass	1774	Pass
1775	Pass	1776	Pass	1777	Pass	1778	Pass
1779	Pass	1780	Pass				

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory