

HYDRO PRESSURE TEST

TC No.: HPT/MA6/A40/RQ/024/26	Model No.: MARQ-6-50%	Date: 11-01-2026
Type and Capacity of Extinguisher	: MARQ-6-50%-Kanex ABC Dry Powder Fire Extinguisher Cap. 6 Kg.	
Batch Number	: MARQ50%6 024/26	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 02301 To 2400 And 2305A	
Month of Manufacturing	: Jan/26	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 2305A and removed from the Lot/Batch							
2301	Pass	2302	Pass	2303	Pass	2304	Pass
2305	Pass	2306	Pass	2307	Pass	2308	Pass
2309	Pass	2310	Pass	2311	Pass	2312	Pass
2313	Pass	2314	Pass	2315	Pass	2316	Pass
2317	Pass	2318	Pass	2319	Pass	2320	Pass
2321	Pass	2322	Pass	2323	Pass	2324	Pass
2325	Pass	2326	Pass	2327	Pass	2328	Pass
2329	Pass	2330	Pass	2331	Pass	2332	Pass
2333	Pass	2334	Pass	2335	Pass	2336	Pass
2337	Pass	2338	Pass	2339	Pass	2340	Pass
2341	Pass	2342	Pass	2343	Pass	2344	Pass
2345	Pass	2346	Pass	2347	Pass	2348	Pass
2349	Pass	2350	Pass	2351	Pass	2352	Pass
2353	Pass	2354	Pass	2355	Pass	2356	Pass
2357	Pass	2358	Pass	2359	Pass	2360	Pass
2361	Pass	2362	Pass	2363	Pass	2364	Pass
2365	Pass	2366	Pass	2367	Pass	2368	Pass
2369	Pass	2370	Pass	2371	Pass	2372	Pass
2373	Pass	2374	Pass	2375	Pass	2376	Pass
2377	Pass	2378	Pass	2379	Pass	2380	Pass
2381	Pass	2382	Pass	2383	Pass	2384	Pass
2385	Pass	2386	Pass	2387	Pass	2388	Pass
2389	Pass	2390	Pass	2391	Pass	2392	Pass
2393	Pass	2394	Pass	2395	Pass	2396	Pass
2397	Pass	2398	Pass	2399	Pass	2400	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory