

HYDRO PRESSURE TEST

TC No.: HPT/MOD5/CA/RQ/072/25	Model No.: KMCRQ-5	Date: 02-12-2025
Type and Capacity of Extinguisher	: KMCRQ-5-Kanex Clean Agent Modular HFC Based Fire Extinguisher Cap. 5 Kg.	
Batch Number	: KMCRQ5 072/25	
Batch Quantity	: 50.00 Nos.	
Serial Numbers	: 03551 To 3600	
Month of Manufacturing	: Dec/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 03551 To 3600 and removed from the Lot/Batch							
3551	Pass	3552	Pass	3553	Pass	3554	Pass
3555	Pass	3556	Pass	3557	Pass	3558	Pass
3559	Pass	3560	Pass	3561	Pass	3562	Pass
3563	Pass	3564	Pass	3565	Pass	3566	Pass
3567	Pass	3568	Pass	3569	Pass	3570	Pass
3571	Pass	3572	Pass	3573	Pass	3574	Pass
3575	Pass	3576	Pass	3577	Pass	3578	Pass
3579	Pass	3580	Pass	3581	Pass	3582	Pass
3583	Pass	3584	Pass	3585	Pass	3586	Pass
3587	Pass	3588	Pass	3589	Pass	3590	Pass
3591	Pass	3592	Pass	3593	Pass	3594	Pass
3595	Pass	3596	Pass	3597	Pass	3598	Pass
3599	Pass	3600	Pass				

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory