

HYDRO PRESSURE TEST

TC No.: HPT/A4/A90/RQ/204/25	Model No.: KFARQ-4-90%	Date: 25-11-2025
Type and Capacity of Extinguisher	: KFARQ-4-90%-Kanex ABC Dry Powder Fire Extinguisher Cap. 4 Kg.	
Batch Number	: KFARQ90%4 204/25	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 20301 To 20400 And 20305A	
Month of Manufacturing	: Nov/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 20305A and removed from the Lot/Batch							
20301	Pass	20302	Pass	20303	Pass	20304	Pass
20305	Pass	20306	Pass	20307	Pass	20308	Pass
20309	Pass	20310	Pass	20311	Pass	20312	Pass
20313	Pass	20314	Pass	20315	Pass	20316	Pass
20317	Pass	20318	Pass	20319	Pass	20320	Pass
20321	Pass	20322	Pass	20323	Pass	20324	Pass
20325	Pass	20326	Pass	20327	Pass	20328	Pass
20329	Pass	20330	Pass	20331	Pass	20332	Pass
20333	Pass	20334	Pass	20335	Pass	20336	Pass
20337	Pass	20338	Pass	20339	Pass	20340	Pass
20341	Pass	20342	Pass	20343	Pass	20344	Pass
20345	Pass	20346	Pass	20347	Pass	20348	Pass
20349	Pass	20350	Pass	20351	Pass	20352	Pass
20353	Pass	20354	Pass	20355	Pass	20356	Pass
20357	Pass	20358	Pass	20359	Pass	20360	Pass
20361	Pass	20362	Pass	20363	Pass	20364	Pass
20365	Pass	20366	Pass	20367	Pass	20368	Pass
20369	Pass	20370	Pass	20371	Pass	20372	Pass
20373	Pass	20374	Pass	20375	Pass	20376	Pass
20377	Pass	20378	Pass	20379	Pass	20380	Pass
20381	Pass	20382	Pass	20383	Pass	20384	Pass
20385	Pass	20386	Pass	20387	Pass	20388	Pass
20389	Pass	20390	Pass	20391	Pass	20392	Pass
20393	Pass	20394	Pass	20395	Pass	20396	Pass
20397	Pass	20398	Pass	20399	Pass	20400	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



SIHOR
(GUJARAT)

Authorized Signatory