

HYDRO PRESSURE TEST

TC No.: HPT/A6/A90/RQ/202/25	Model No.: KFARQ-6-90%	Date: 20-07-2025
Type and Capacity of Extinguisher	: KFARQ-6-90%-Kanex ABC Dry Powder Fire Extinguisher Cap. 6 Kg.	
Batch Number	: KFARQ90%6 202/25	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 20101 To 20200 And 20105A	
Month of Manufacturing	: Jul/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 20105A and removed from the Lot/Batch							
20101	Pass	20102	Pass	20103	Pass	20104	Pass
20105	Pass	20106	Pass	20107	Pass	20108	Pass
20109	Pass	20110	Pass	20111	Pass	20112	Pass
20113	Pass	20114	Pass	20115	Pass	20116	Pass
20117	Pass	20118	Pass	20119	Pass	20120	Pass
20121	Pass	20122	Pass	20123	Pass	20124	Pass
20125	Pass	20126	Pass	20127	Pass	20128	Pass
20129	Pass	20130	Pass	20131	Pass	20132	Pass
20133	Pass	20134	Pass	20135	Pass	20136	Pass
20137	Pass	20138	Pass	20139	Pass	20140	Pass
20141	Pass	20142	Pass	20143	Pass	20144	Pass
20145	Pass	20146	Pass	20147	Pass	20148	Pass
20149	Pass	20150	Pass	20151	Pass	20152	Pass
20153	Pass	20154	Pass	20155	Pass	20156	Pass
20157	Pass	20158	Pass	20159	Pass	20160	Pass
20161	Pass	20162	Pass	20163	Pass	20164	Pass
20165	Pass	20166	Pass	20167	Pass	20168	Pass
20169	Pass	20170	Pass	20171	Pass	20172	Pass
20173	Pass	20174	Pass	20175	Pass	20176	Pass
20177	Pass	20178	Pass	20179	Pass	20180	Pass
20181	Pass	20182	Pass	20183	Pass	20184	Pass
20185	Pass	20186	Pass	20187	Pass	20188	Pass
20189	Pass	20190	Pass	20191	Pass	20192	Pass
20193	Pass	20194	Pass	20195	Pass	20196	Pass
20197	Pass	20198	Pass	20199	Pass	20200	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory