

HYDRO PRESSURE TEST

TC No.: HPT/A4/A50/RQ/072/25	Model No.: KFARQ-4-50%	Date: 08-09-2025
Type and Capacity of Extinguisher	: KFARQ-4-50%-Kanex ABC Dry Powder Fire Extinguisher Cap. 4 Kg.	
Batch Number	: KFARQ50%4 072/25	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 07101 To 7200 And 7105A	
Month of Manufacturing	: Sep/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 7105A and removed from the Lot/Batch							
7101	Pass	7102	Pass	7103	Pass	7104	Pass
7105	Pass	7106	Pass	7107	Pass	7108	Pass
7109	Pass	7110	Pass	7111	Pass	7112	Pass
7113	Pass	7114	Pass	7115	Pass	7116	Pass
7117	Pass	7118	Pass	7119	Pass	7120	Pass
7121	Pass	7122	Pass	7123	Pass	7124	Pass
7125	Pass	7126	Pass	7127	Pass	7128	Pass
7129	Pass	7130	Pass	7131	Pass	7132	Pass
7133	Pass	7134	Pass	7135	Pass	7136	Pass
7137	Pass	7138	Pass	7139	Pass	7140	Pass
7141	Pass	7142	Pass	7143	Pass	7144	Pass
7145	Pass	7146	Pass	7147	Pass	7148	Pass
7149	Pass	7150	Pass	7151	Pass	7152	Pass
7153	Pass	7154	Pass	7155	Pass	7156	Pass
7157	Pass	7158	Pass	7159	Pass	7160	Pass
7161	Pass	7162	Pass	7163	Pass	7164	Pass
7165	Pass	7166	Pass	7167	Pass	7168	Pass
7169	Pass	7170	Pass	7171	Pass	7172	Pass
7173	Pass	7174	Pass	7175	Pass	7176	Pass
7177	Pass	7178	Pass	7179	Pass	7180	Pass
7181	Pass	7182	Pass	7183	Pass	7184	Pass
7185	Pass	7186	Pass	7187	Pass	7188	Pass
7189	Pass	7190	Pass	7191	Pass	7192	Pass
7193	Pass	7194	Pass	7195	Pass	7196	Pass
7197	Pass	7198	Pass	7199	Pass	7200	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory