

HYDRO PRESSURE TEST

TC No.: HPT/A6/A90/RQ/257/25	Model No.: KFARQ-6-90%	Date: 26-09-2025
Type and Capacity of Extinguisher	: KFARQ-6-90%-Kanex ABC Dry Powder Fire Extinguisher Cap. 6 Kg.	
Batch Number	: KFARQ90%6 257/25	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 25601 To 25700 And 25605A	
Month of Manufacturing	: Sep/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 25605A and removed from the Lot/Batch							
25601	Pass	25602	Pass	25603	Pass	25604	Pass
25605	Pass	25606	Pass	25607	Pass	25608	Pass
25609	Pass	25610	Pass	25611	Pass	25612	Pass
25613	Pass	25614	Pass	25615	Pass	25616	Pass
25617	Pass	25618	Pass	25619	Pass	25620	Pass
25621	Pass	25622	Pass	25623	Pass	25624	Pass
25625	Pass	25626	Pass	25627	Pass	25628	Pass
25629	Pass	25630	Pass	25631	Pass	25632	Pass
25633	Pass	25634	Pass	25635	Pass	25636	Pass
25637	Pass	25638	Pass	25639	Pass	25640	Pass
25641	Pass	25642	Pass	25643	Pass	25644	Pass
25645	Pass	25646	Pass	25647	Pass	25648	Pass
25649	Pass	25650	Pass	25651	Pass	25652	Pass
25653	Pass	25654	Pass	25655	Pass	25656	Pass
25657	Pass	25658	Pass	25659	Pass	25660	Pass
25661	Pass	25662	Pass	25663	Pass	25664	Pass
25665	Pass	25666	Pass	25667	Pass	25668	Pass
25669	Pass	25670	Pass	25671	Pass	25672	Pass
25673	Pass	25674	Pass	25675	Pass	25676	Pass
25677	Pass	25678	Pass	25679	Pass	25680	Pass
25681	Pass	25682	Pass	25683	Pass	25684	Pass
25685	Pass	25686	Pass	25687	Pass	25688	Pass
25689	Pass	25690	Pass	25691	Pass	25692	Pass
25693	Pass	25694	Pass	25695	Pass	25696	Pass
25697	Pass	25698	Pass	25699	Pass	25700	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory