

HYDRO PRESSURE TEST

TC No.: HPT/A4/A90/RQ/176/25	Model No.: KFARQ-4-90%	Date: 04-10-2025
Type and Capacity of Extinguisher	: KFARQ-4-90%-Kanex ABC Dry Powder Fire Extinguisher Cap. 4 Kg.	
Batch Number	: KFARQ90%4 176/25	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 17501 To 17600 And 17505A	
Month of Manufacturing	: Oct/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 17505A and removed from the Lot/Batch							
17501	Pass	17502	Pass	17503	Pass	17504	Pass
17505	Pass	17506	Pass	17507	Pass	17508	Pass
17509	Pass	17510	Pass	17511	Pass	17512	Pass
17513	Pass	17514	Pass	17515	Pass	17516	Pass
17517	Pass	17518	Pass	17519	Pass	17520	Pass
17521	Pass	17522	Pass	17523	Pass	17524	Pass
17525	Pass	17526	Pass	17527	Pass	17528	Pass
17529	Pass	17530	Pass	17531	Pass	17532	Pass
17533	Pass	17534	Pass	17535	Pass	17536	Pass
17537	Pass	17538	Pass	17539	Pass	17540	Pass
17541	Pass	17542	Pass	17543	Pass	17544	Pass
17545	Pass	17546	Pass	17547	Pass	17548	Pass
17549	Pass	17550	Pass	17551	Pass	17552	Pass
17553	Pass	17554	Pass	17555	Pass	17556	Pass
17557	Pass	17558	Pass	17559	Pass	17560	Pass
17561	Pass	17562	Pass	17563	Pass	17564	Pass
17565	Pass	17566	Pass	17567	Pass	17568	Pass
17569	Pass	17570	Pass	17571	Pass	17572	Pass
17573	Pass	17574	Pass	17575	Pass	17576	Pass
17577	Pass	17578	Pass	17579	Pass	17580	Pass
17581	Pass	17582	Pass	17583	Pass	17584	Pass
17585	Pass	17586	Pass	17587	Pass	17588	Pass
17589	Pass	17590	Pass	17591	Pass	17592	Pass
17593	Pass	17594	Pass	17595	Pass	17596	Pass
17597	Pass	17598	Pass	17599	Pass	17600	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory