

HYDRO PRESSURE TEST

TC No.: HPT/A6/A90/RQ/253/25	Model No.: KFARQ-6-90%	Date: 22-09-2025
Type and Capacity of Extinguisher	: KFARQ-6-90%-Kanex ABC Dry Powder Fire Extinguisher Cap. 6 Kg.	
Batch Number	: KFARQ90%6 253/25	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 25201 To 25300 And 25205A	
Month of Manufacturing	: Sep/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 25205A and removed from the Lot/Batch							
25201	Pass	25202	Pass	25203	Pass	25204	Pass
25205	Pass	25206	Pass	25207	Pass	25208	Pass
25209	Pass	25210	Pass	25211	Pass	25212	Pass
25213	Pass	25214	Pass	25215	Pass	25216	Pass
25217	Pass	25218	Pass	25219	Pass	25220	Pass
25221	Pass	25222	Pass	25223	Pass	25224	Pass
25225	Pass	25226	Pass	25227	Pass	25228	Pass
25229	Pass	25230	Pass	25231	Pass	25232	Pass
25233	Pass	25234	Pass	25235	Pass	25236	Pass
25237	Pass	25238	Pass	25239	Pass	25240	Pass
25241	Pass	25242	Pass	25243	Pass	25244	Pass
25245	Pass	25246	Pass	25247	Pass	25248	Pass
25249	Pass	25250	Pass	25251	Pass	25252	Pass
25253	Pass	25254	Pass	25255	Pass	25256	Pass
25257	Pass	25258	Pass	25259	Pass	25260	Pass
25261	Pass	25262	Pass	25263	Pass	25264	Pass
25265	Pass	25266	Pass	25267	Pass	25268	Pass
25269	Pass	25270	Pass	25271	Pass	25272	Pass
25273	Pass	25274	Pass	25275	Pass	25276	Pass
25277	Pass	25278	Pass	25279	Pass	25280	Pass
25281	Pass	25282	Pass	25283	Pass	25284	Pass
25285	Pass	25286	Pass	25287	Pass	25288	Pass
25289	Pass	25290	Pass	25291	Pass	25292	Pass
25293	Pass	25294	Pass	25295	Pass	25296	Pass
25297	Pass	25298	Pass	25299	Pass	25300	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory