

# HYDRO PRESSURE TEST

|                                   |                                                                            |                  |
|-----------------------------------|----------------------------------------------------------------------------|------------------|
| TC No.: HPT/MOD5/CA/RQ/059/25     | Model No.: KMCRQ-5                                                         | Date: 27-08-2025 |
| Type and Capacity of Extinguisher | : KMCRQ-5-Kanex Clean Agent Modular HFC Based Fire Extinguisher Cap. 5 Kg. |                  |
| Batch Number                      | : KMCRQ5 059/25                                                            |                  |
| Batch Quantity                    | : 50.00 Nos.                                                               |                  |
| Serial Numbers                    | : 02901 To 2950                                                            |                  |
| Month of Manufacturing            | : Aug/25                                                                   |                  |

| Sr. Nos.                                                             | Result | Sr. Nos. | Result | Sr. Nos. | Result | Sr. Nos. | Result |
|----------------------------------------------------------------------|--------|----------|--------|----------|--------|----------|--------|
| Burst test conducted on 02901 To 2950 and removed from the Lot/Batch |        |          |        |          |        |          |        |
| 2901                                                                 | Pass   | 2902     | Pass   | 2903     | Pass   | 2904     | Pass   |
| 2905                                                                 | Pass   | 2906     | Pass   | 2907     | Pass   | 2908     | Pass   |
| 2909                                                                 | Pass   | 2910     | Pass   | 2911     | Pass   | 2912     | Pass   |
| 2913                                                                 | Pass   | 2914     | Pass   | 2915     | Pass   | 2916     | Pass   |
| 2917                                                                 | Pass   | 2918     | Pass   | 2919     | Pass   | 2920     | Pass   |
| 2921                                                                 | Pass   | 2922     | Pass   | 2923     | Pass   | 2924     | Pass   |
| 2925                                                                 | Pass   | 2926     | Pass   | 2927     | Pass   | 2928     | Pass   |
| 2929                                                                 | Pass   | 2930     | Pass   | 2931     | Pass   | 2932     | Pass   |
| 2933                                                                 | Pass   | 2934     | Pass   | 2935     | Pass   | 2936     | Pass   |
| 2937                                                                 | Pass   | 2938     | Pass   | 2939     | Pass   | 2940     | Pass   |
| 2941                                                                 | Pass   | 2942     | Pass   | 2943     | Pass   | 2944     | Pass   |
| 2945                                                                 | Pass   | 2946     | Pass   | 2947     | Pass   | 2948     | Pass   |
| 2949                                                                 | Pass   | 2950     | Pass   |          |        |          |        |

**Remarks:** This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



**Authorized Signatory**