

HYDRO PRESSURE TEST

TC No.: HPT/A6/A90/RQ/252/25	Model No.: KFARQ-6-90%	Date: 22-09-2025
Type and Capacity of Extinguisher	: KFARQ-6-90%-Kanex ABC Dry Powder Fire Extinguisher Cap. 6 Kg.	
Batch Number	: KFARQ90%6 252/25	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 25101 To 25200 And 25105A	
Month of Manufacturing	: Sep/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 25105A and removed from the Lot/Batch							
25101	Pass	25102	Pass	25103	Pass	25104	Pass
25105	Pass	25106	Pass	25107	Pass	25108	Pass
25109	Pass	25110	Pass	25111	Pass	25112	Pass
25113	Pass	25114	Pass	25115	Pass	25116	Pass
25117	Pass	25118	Pass	25119	Pass	25120	Pass
25121	Pass	25122	Pass	25123	Pass	25124	Pass
25125	Pass	25126	Pass	25127	Pass	25128	Pass
25129	Pass	25130	Pass	25131	Pass	25132	Pass
25133	Pass	25134	Pass	25135	Pass	25136	Pass
25137	Pass	25138	Pass	25139	Pass	25140	Pass
25141	Pass	25142	Pass	25143	Pass	25144	Pass
25145	Pass	25146	Pass	25147	Pass	25148	Pass
25149	Pass	25150	Pass	25151	Pass	25152	Pass
25153	Pass	25154	Pass	25155	Pass	25156	Pass
25157	Pass	25158	Pass	25159	Pass	25160	Pass
25161	Pass	25162	Pass	25163	Pass	25164	Pass
25165	Pass	25166	Pass	25167	Pass	25168	Pass
25169	Pass	25170	Pass	25171	Pass	25172	Pass
25173	Pass	25174	Pass	25175	Pass	25176	Pass
25177	Pass	25178	Pass	25179	Pass	25180	Pass
25181	Pass	25182	Pass	25183	Pass	25184	Pass
25185	Pass	25186	Pass	25187	Pass	25188	Pass
25189	Pass	25190	Pass	25191	Pass	25192	Pass
25193	Pass	25194	Pass	25195	Pass	25196	Pass
25197	Pass	25198	Pass	25199	Pass	25200	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory