

HYDRO PRESSURE TEST

TC No.: HPT/A6/A50/RQ/326/25	Model No.: KFARQ-6-50%	Date: 03-11-2025
Type and Capacity of Extinguisher	: KFARQ-6-50%-Kanex ABC Dry Powder Fire Extinguisher Cap. 6 Kg.	
Batch Number	: KFARQ50%6 326/25	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 32501 To 32600 And 32505A	
Month of Manufacturing	: Nov/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 32505A and removed from the Lot/Batch							
32501	Pass	32502	Pass	32503	Pass	32504	Pass
32505	Pass	32506	Pass	32507	Pass	32508	Pass
32509	Pass	32510	Pass	32511	Pass	32512	Pass
32513	Pass	32514	Pass	32515	Pass	32516	Pass
32517	Pass	32518	Pass	32519	Pass	32520	Pass
32521	Pass	32522	Pass	32523	Pass	32524	Pass
32525	Pass	32526	Pass	32527	Pass	32528	Pass
32529	Pass	32530	Pass	32531	Pass	32532	Pass
32533	Pass	32534	Pass	32535	Pass	32536	Pass
32537	Pass	32538	Pass	32539	Pass	32540	Pass
32541	Pass	32542	Pass	32543	Pass	32544	Pass
32545	Pass	32546	Pass	32547	Pass	32548	Pass
32549	Pass	32550	Pass	32551	Pass	32552	Pass
32553	Pass	32554	Pass	32555	Pass	32556	Pass
32557	Pass	32558	Pass	32559	Pass	32560	Pass
32561	Pass	32562	Pass	32563	Pass	32564	Pass
32565	Pass	32566	Pass	32567	Pass	32568	Pass
32569	Pass	32570	Pass	32571	Pass	32572	Pass
32573	Pass	32574	Pass	32575	Pass	32576	Pass
32577	Pass	32578	Pass	32579	Pass	32580	Pass
32581	Pass	32582	Pass	32583	Pass	32584	Pass
32585	Pass	32586	Pass	32587	Pass	32588	Pass
32589	Pass	32590	Pass	32591	Pass	32592	Pass
32593	Pass	32594	Pass	32595	Pass	32596	Pass
32597	Pass	32598	Pass	32599	Pass	32600	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory