

QMF01	Declaration of Conformity DoC	    Assessed to ISO 9001 Cert/LPCB ref No 085 Cert No FM 59294
Doc Page No: 1 of 1		
Revision: 3		
Issue Date: 22/08/2023		
Authorised By: T.Swadzba		

Bailey & Mackey Ltd

Pressure Switch, Pressure Gauge and
 Pressure Transducer Manufacture
 Baltimore Road, Birmingham, B42 1DE
 Tel: 0121 357 5351
 Fax: 0121 357 8319
 E-mail: enquiries@baileymackey.com
 Registered in England No. 2140400

Declaration of Conformance

Customer:

KANEX FIRE SOLUTIONS LIMITED
 PLOT NO 7 PARAS INDUSTRIAL ESTATE
 NEAR GARIBSHA PIR DARGAH
 SIHOR 364240
 GUJARAT
 INDIA

JOB No: 00E8475 ENTERED: 23/05/25 YOUR ORDER No: 16806

SPEC: AS DESCRIPTION QTY: 2000

SERIAL No: 25 E8475 0001 to 25 E8475 2000 inclusive.

DESCRIPTION	
	TYPE 12 P. SWITCH, RANGE 5/35 bar. BRASS BASE Be. Cu. DIAPHRAGM, EPDM SEAL CONNECTION M10x1 C/W Z080E SINTERED FILTER IN PRESSURE PASSAGE TO DRG K601P SPDT MICRO SWITCH RATED 5A 250V 50HZ C/W 0.5M 4 CORE CABLE BROWN/ BLACK/ GREY/ EARTH FITTED WITH HEX GRUB SCREW. INTERNAL ADJUSTER SET AT 5 BAR FALLING MANUFACTURED IN ACCORDANCE TO S.E.P. REF PED – 2014/68/EC CE MARKED IN ACCORDANCE WITH THE LOW VOLTAGE DIRECTIVE 2014/35/EU

CERTIFIED THAT THE WHOLE OF THE SUPPLIES DETAILED HEREON HAVE BEEN INSPECTED, TESTED AND UNLESS OTHERWISE STATED CONFORM IN ALL RESPECTS WITH DETAILS OF THE CONTRACT OR ORDER AS DETAILED HEREWITH.

ALL TEST EQUIPMENT USED IN CONNECTION WITH THIS ORDER IS CERTIFIED TRACEABLE TO NATIONAL STANDARDS IN ACCORDANCE WITH REQUIREMENTS BS EN ISO 9001:2015

SIGNED: P Bolstridge POSITION: Q/A Department DATE: 28/07/25