

HYDRO PRESSURE TEST

TC No.: HPT/A4/A50/RQ/080/25	Model No.: KFARQ-4-50%	Date: 26-10-2025
Type and Capacity of Extinguisher	: KFARQ-4-50%-Kanex ABC Dry Powder Fire Extinguisher Cap. 4 Kg.	
Batch Number	: KFARQ50%4 080/25	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 07901 To 8000 And 7905A	
Month of Manufacturing	: Oct/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 7905A and removed from the Lot/Batch							
7901	Pass	7902	Pass	7903	Pass	7904	Pass
7905	Pass	7906	Pass	7907	Pass	7908	Pass
7909	Pass	7910	Pass	7911	Pass	7912	Pass
7913	Pass	7914	Pass	7915	Pass	7916	Pass
7917	Pass	7918	Pass	7919	Pass	7920	Pass
7921	Pass	7922	Pass	7923	Pass	7924	Pass
7925	Pass	7926	Pass	7927	Pass	7928	Pass
7929	Pass	7930	Pass	7931	Pass	7932	Pass
7933	Pass	7934	Pass	7935	Pass	7936	Pass
7937	Pass	7938	Pass	7939	Pass	7940	Pass
7941	Pass	7942	Pass	7943	Pass	7944	Pass
7945	Pass	7946	Pass	7947	Pass	7948	Pass
7949	Pass	7950	Pass	7951	Pass	7952	Pass
7953	Pass	7954	Pass	7955	Pass	7956	Pass
7957	Pass	7958	Pass	7959	Pass	7960	Pass
7961	Pass	7962	Pass	7963	Pass	7964	Pass
7965	Pass	7966	Pass	7967	Pass	7968	Pass
7969	Pass	7970	Pass	7971	Pass	7972	Pass
7973	Pass	7974	Pass	7975	Pass	7976	Pass
7977	Pass	7978	Pass	7979	Pass	7980	Pass
7981	Pass	7982	Pass	7983	Pass	7984	Pass
7985	Pass	7986	Pass	7987	Pass	7988	Pass
7989	Pass	7990	Pass	7991	Pass	7992	Pass
7993	Pass	7994	Pass	7995	Pass	7996	Pass
7997	Pass	7998	Pass	7999	Pass	8000	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory