

HYDRO PRESSURE TEST

TC No.: HPT/MOD5/CA/RQ/068/25	Model No.: KMCRQ-5	Date: 04-10-2025
Type and Capacity of Extinguisher	: KMCRQ-5-Kanex Clean Agent Modular HFC Based Fire Extinguisher Cap. 5 Kg.	
Batch Number	: KMCRQ5 068/25	
Batch Quantity	: 50.00 Nos.	
Serial Numbers	: 03351 To 3400	
Month of Manufacturing	: Oct/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 03351 To 3400 and removed from the Lot/Batch							
3351	Pass	3352	Pass	3353	Pass	3354	Pass
3355	Pass	3356	Pass	3357	Pass	3358	Pass
3359	Pass	3360	Pass	3361	Pass	3362	Pass
3363	Pass	3364	Pass	3365	Pass	3366	Pass
3367	Pass	3368	Pass	3369	Pass	3370	Pass
3371	Pass	3372	Pass	3373	Pass	3374	Pass
3375	Pass	3376	Pass	3377	Pass	3378	Pass
3379	Pass	3380	Pass	3381	Pass	3382	Pass
3383	Pass	3384	Pass	3385	Pass	3386	Pass
3387	Pass	3388	Pass	3389	Pass	3390	Pass
3391	Pass	3392	Pass	3393	Pass	3394	Pass
3395	Pass	3396	Pass	3397	Pass	3398	Pass
3399	Pass	3400	Pass				

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory