




Certificate No.
AFX/25-26/TC-18
Issuing Date: 18.07.2025
Order No.: PO#17175-0
Date: 18/06/2025

Issued To:
Kanex Fire Solutions Ltd.
Plot No.: 7, Paras Industrial Estate, Near
Garibsha Pir Dargah, Sihor, Dist.: Bhavnagar,
State: Gujarat, Pincode: 364240

Batch Test Record	
Product:	AFX EOL Assembly
Build Date	02/04/2025
Criteria	10 Units Random Samples drawn from each Batch (Batch = 1 x 100 Nos)
Time- From-To	11:00-12:15
Conducted By	Narayan

AFX Pick ticket Nos./Lot/Batch Nos.	Serial Nos.	Qty. Inspected.
PKT No. 29 to 45 Lot No. 03/2025		500 Nos.
		500 Nos.

AutoFireX® EOL Assembly: Part Number 200121		Description	Material Specification	Visual Inspection Result
		Hex Flat	Threaded SW12	Pass
		Schrader Adaptor Thread size	M 10 x 1 (As per EN3)	Pass
		Pressure Gauge (Removable)	AutoFireX® Generic Pressure Gauge – M 10 x1; 12.5mm Brass Nickle coated with Pressure & temperature Grading made to DIN ISO 1302; DIN 6784	Pass
		EOL Body	Chrome Nickel-plated Brass Body with PTFE Seats, NBR Seal O-RING, L-71mm	Pass
		Dual Seal Tube Connection	6mm OD - G 1/8" suitable for Threaded Dual Seal Slip on Union fitting	Pass

Test Category	Test	Acceptance Criteria	Result
Physical & Mechanical	Weight	<90gms	 Pass
	MOC confirmation	Standard: Brass, Nickel, Chrome Plated	
	Dimensions	Doc – AFX- 0021 Rev July 2020	
	Serial No.	181011CA	
	O Ring Seal dia.	<2mm	
	Test Category	Test	Acceptance Criteria
	Mechanical	Wall Thickness	Pass
		Tensile	
		Yield	
		Elongation	
	Hydrostatic	Expansion @ 720 psig	Pass
		Permanent Expansion	Pass
		Expansion Ratio	Pass
		Capacity	Pass
	Physical Analysis	Steel per...	SS304
Pressure Test	Operational Pressure Normal	@15-20 Bar	Pass
	Burst/ Fail Pressure	@140 Bar	Pass
Temperature Test	Operational Temperature	21°C @ 15 Bar	Pass
	High Temperature Test (Oven Test)	80°C @ 18 Bar	Pass
Leakage Test	High Pressure	40 Bar @ 21°C	Pass
Test Conducted By	Narayan		
Signature			
Date	18/07/25		
Attested By	Pawan Kumar		
Signature			
Date	18/07/25		

TC/CCL ISSUED TO:
KANEX FIRE SOLUTIONS LTD.
Ref. No. PO-17175-0 / 18/06/25
FOR AUTO FIREX LLP

Authorised Signatory