

HYDRO PRESSURE TEST

TC No.: HPT/A3/K/HQ/022/25	Model No.: KFKHQ-3	Date: 26-09-2025
Type and Capacity of Extinguisher	: KFKHQ-3-Kanex F Class Kitchen Fire Extinguisher Cap. 3 Ltr.	
Batch Number	: KFKHQ3 022/25	
Batch Quantity	: 11.00 Nos.	
Serial Numbers	: 00211 To 220 And 215A	
Month of Manufacturing	: Sep/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 215A and removed from the Lot/Batch							
211	Pass	212	Pass	213	Pass	214	Pass
215	Pass	216	Pass	217	Pass	218	Pass
219	Pass	220	Pass				

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory