

Declaration of Conformity/Routine Test Certificate

Issued To:	
Kanadia Fyr Fyter Pvt.Ltd. Plot No.7 Paras Industrial Estate Near Garibsha Pir Dargah Sihor-364240 Gujarat	Certificate No. AFX/TC/CFE/92 Date of Issue 09/12/2023

Batch Test Record

Product:	Red UL – Fire Detection Tube (FDT) 4 x 6mm
Lot Size	30000 Mtr.
Date	17/11/2023
Criteria	50 Units Random Samples (100M Coil) drawn from each Lot
Conducted By	NARAYAN

Brand/Part Number	Pick ticket Nos./Lot/Batch Nos.	Batch No.	Qty. Inspected.
KANEX/7000600	KNXROBK230718/06	146920	10000 Mtr.

Test Category	Test	Acceptance Criteria	Result
Physical & Mechanical	Coil Weight	< 1.71Kg	Pass QC 01
	Colour confirmation	Standard Red	
	Print Matter	Standard	
	Wall Thickness OD/ID	6mm OD x 4mm ID	
	Tolerance	1 mm (+0.1 mm/-0.2 mm)	
	Bend Radius	<25cm	
	CHARACTERISTICS	METHOD	Pass QC 01
	Internal diameter (ID)	Plug gauge CT004 OKNOK	
	Outside diameter (OD)	Ring gauge CT004 OKNOK	
	Wall Thickness - lowest point	Vernier Dim 1mm 0.9 1.09	
	Wall Thickness - highest point	Vernier Dim 1mm 0.9 1.09	
	Length - Check Against Datasheet	Measure Length OK	
	Print	Visual OKNOK OK	
	Colour	Visual OKNOK OK	
	Finish	Visual OKNOK OK	
	Coiling / Packaging as per data sheet	Visual OKNOK OK	
Pressure Test	Operational Pressure Normal	13.5 Bar (195 psi) @ 21°C	Pass
	Max Hydrostatic Burst Pressure	< 75 Bar	Pass
Temperature Test	Operational Temperature	135°C – 204°C @ 13.5 Bar	Pass
	Oven Test & High Temperature Exposure Test	Complying to UL 521 Section 19.1 & 21.1	Pass
	Operating Temperature Test	Complying to UL 521 Section 22.2	Pass
Leakage Test	High Operational Pressure	< 20 Bar	Pass

Test Conducted By	NARAYAN – Technician
Signature	
Date	9-12-23

TC/COC ISSUED TO:

M/S KANADIA FYR FYTER

PVT. LTD.

Ref. No. PO#11263/16-11-23

FOR KANEX LLP

Authorised by 11/2/23