



Warranty Certificate

Date: 13-12-2025

Manufacturer: Kanex Fire Solutions Limited.

Customer Name: Haryana Leather Chemicals LtdWarranty Start Date: 13-12-2025Warranty End Date: 12-12-2026.

This is to certify that the below extinguishers are warranted for a period of **1** year from the date of supply against any of Manufacturing/Quality defects.

NOTE – IF TAMPER SEAL IS NOT INTACT, THE WARRANTY SHALL BE CONSIDERED VOID.

Sr.No.	Type & Capacity of Extinguishers	Quantity	Sr. Nos.
1	KCARQ-2-Kanex Clean Agent HFC Based Fire Extinguisher Cap. 2 Kg.	1	As Per Annexure – I
2	KFARQ-4-90%-Kanex ABC Dry Powder Fire Extinguisher Cap. 4 Kg.	1	As Per Annexure – I

Also certify that, all the Fire extinguishers supplied against Invoice No. **25-26/N/000516 Dated: 13-12-2025 P.O.No. HLCL/PEIPL/2025** are hydraulically tested 100% at 35 bar except CO2 and randomly tested for performance test. All the extinguishers confirms to IS 15683:2018 (Portable) or IS 16018:2012 (Mobile) requirements.

Note : If applicable CO2 Cylinders are PESO approved & HPT tested at 225 bar by Cylinder Manufacturer.



Authorized Signatory

