

HYDRO PRESSURE TEST

TC No.: HPT/A4/A90/RQ/181/25	Model No.: KFARQ-4-90%	Date: 07-10-2025
Type and Capacity of Extinguisher	: KFARQ-4-90%-Kanex ABC Dry Powder Fire Extinguisher Cap. 4 Kg.	
Batch Number	: KFARQ90%4 181/25	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 18001 To 18100 And 18005A	
Month of Manufacturing	: Oct/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 18005A and removed from the Lot/Batch							
18001	Pass	18002	Pass	18003	Pass	18004	Pass
18005	Pass	18006	Pass	18007	Pass	18008	Pass
18009	Pass	18010	Pass	18011	Pass	18012	Pass
18013	Pass	18014	Pass	18015	Pass	18016	Pass
18017	Pass	18018	Pass	18019	Pass	18020	Pass
18021	Pass	18022	Pass	18023	Pass	18024	Pass
18025	Pass	18026	Pass	18027	Pass	18028	Pass
18029	Pass	18030	Pass	18031	Pass	18032	Pass
18033	Pass	18034	Pass	18035	Pass	18036	Pass
18037	Pass	18038	Pass	18039	Pass	18040	Pass
18041	Pass	18042	Pass	18043	Pass	18044	Pass
18045	Pass	18046	Pass	18047	Pass	18048	Pass
18049	Pass	18050	Pass	18051	Pass	18052	Pass
18053	Pass	18054	Pass	18055	Pass	18056	Pass
18057	Pass	18058	Pass	18059	Pass	18060	Pass
18061	Pass	18062	Pass	18063	Pass	18064	Pass
18065	Pass	18066	Pass	18067	Pass	18068	Pass
18069	Pass	18070	Pass	18071	Pass	18072	Pass
18073	Pass	18074	Pass	18075	Pass	18076	Pass
18077	Pass	18078	Pass	18079	Pass	18080	Pass
18081	Pass	18082	Pass	18083	Pass	18084	Pass
18085	Pass	18086	Pass	18087	Pass	18088	Pass
18089	Pass	18090	Pass	18091	Pass	18092	Pass
18093	Pass	18094	Pass	18095	Pass	18096	Pass
18097	Pass	18098	Pass	18099	Pass	18100	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory