

HYDRO PRESSURE TEST

TC No.: HPT/A4/A90/RQ/183/25	Model No.: KFARQ-4-90%	Date: 07-10-2025
Type and Capacity of Extinguisher	: KFARQ-4-90%-Kanex ABC Dry Powder Fire Extinguisher Cap. 4 Kg.	
Batch Number	: KFARQ90%4 183/25	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 18201 To 18300 And 18205A	
Month of Manufacturing	: Oct/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 18205A and removed from the Lot/Batch							
18201	Pass	18202	Pass	18203	Pass	18204	Pass
18205	Pass	18206	Pass	18207	Pass	18208	Pass
18209	Pass	18210	Pass	18211	Pass	18212	Pass
18213	Pass	18214	Pass	18215	Pass	18216	Pass
18217	Pass	18218	Pass	18219	Pass	18220	Pass
18221	Pass	18222	Pass	18223	Pass	18224	Pass
18225	Pass	18226	Pass	18227	Pass	18228	Pass
18229	Pass	18230	Pass	18231	Pass	18232	Pass
18233	Pass	18234	Pass	18235	Pass	18236	Pass
18237	Pass	18238	Pass	18239	Pass	18240	Pass
18241	Pass	18242	Pass	18243	Pass	18244	Pass
18245	Pass	18246	Pass	18247	Pass	18248	Pass
18249	Pass	18250	Pass	18251	Pass	18252	Pass
18253	Pass	18254	Pass	18255	Pass	18256	Pass
18257	Pass	18258	Pass	18259	Pass	18260	Pass
18261	Pass	18262	Pass	18263	Pass	18264	Pass
18265	Pass	18266	Pass	18267	Pass	18268	Pass
18269	Pass	18270	Pass	18271	Pass	18272	Pass
18273	Pass	18274	Pass	18275	Pass	18276	Pass
18277	Pass	18278	Pass	18279	Pass	18280	Pass
18281	Pass	18282	Pass	18283	Pass	18284	Pass
18285	Pass	18286	Pass	18287	Pass	18288	Pass
18289	Pass	18290	Pass	18291	Pass	18292	Pass
18293	Pass	18294	Pass	18295	Pass	18296	Pass
18297	Pass	18298	Pass	18299	Pass	18300	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory