

HYDRO PRESSURE TEST

TC No.: HPT/A4/A50/RQ/097/25	Model No.: KFARQ-4-50%	Date: 25-11-2025
Type and Capacity of Extinguisher	: KFARQ-4-50%-Kanex ABC Dry Powder Fire Extinguisher Cap. 4 Kg.	
Batch Number	: KFARQ50%4 097/25	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 09601 To 9700 And 9605A	
Month of Manufacturing	: Nov/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 9605A and removed from the Lot/Batch							
9601	Pass	9602	Pass	9603	Pass	9604	Pass
9605	Pass	9606	Pass	9607	Pass	9608	Pass
9609	Pass	9610	Pass	9611	Pass	9612	Pass
9613	Pass	9614	Pass	9615	Pass	9616	Pass
9617	Pass	9618	Pass	9619	Pass	9620	Pass
9621	Pass	9622	Pass	9623	Pass	9624	Pass
9625	Pass	9626	Pass	9627	Pass	9628	Pass
9629	Pass	9630	Pass	9631	Pass	9632	Pass
9633	Pass	9634	Pass	9635	Pass	9636	Pass
9637	Pass	9638	Pass	9639	Pass	9640	Pass
9641	Pass	9642	Pass	9643	Pass	9644	Pass
9645	Pass	9646	Pass	9647	Pass	9648	Pass
9649	Pass	9650	Pass	9651	Pass	9652	Pass
9653	Pass	9654	Pass	9655	Pass	9656	Pass
9657	Pass	9658	Pass	9659	Pass	9660	Pass
9661	Pass	9662	Pass	9663	Pass	9664	Pass
9665	Pass	9666	Pass	9667	Pass	9668	Pass
9669	Pass	9670	Pass	9671	Pass	9672	Pass
9673	Pass	9674	Pass	9675	Pass	9676	Pass
9677	Pass	9678	Pass	9679	Pass	9680	Pass
9681	Pass	9682	Pass	9683	Pass	9684	Pass
9685	Pass	9686	Pass	9687	Pass	9688	Pass
9689	Pass	9690	Pass	9691	Pass	9692	Pass
9693	Pass	9694	Pass	9695	Pass	9696	Pass
9697	Pass	9698	Pass	9699	Pass	9700	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory