

HYDRO PRESSURE TEST

TC No.: HPT/A6/A90/RQ/278/25	Model No.: KFARQ-6-90%	Date: 25-11-2025
Type and Capacity of Extinguisher	: KFARQ-6-90%-Kanex ABC Dry Powder Fire Extinguisher Cap. 6 Kg.	
Batch Number	: KFARQ90%6 278/25	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 27701 To 27800 And 27705A	
Month of Manufacturing	: Nov/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 27705A and removed from the Lot/Batch							
27701	Pass	27702	Pass	27703	Pass	27704	Pass
27705	Pass	27706	Pass	27707	Pass	27708	Pass
27709	Pass	27710	Pass	27711	Pass	27712	Pass
27713	Pass	27714	Pass	27715	Pass	27716	Pass
27717	Pass	27718	Pass	27719	Pass	27720	Pass
27721	Pass	27722	Pass	27723	Pass	27724	Pass
27725	Pass	27726	Pass	27727	Pass	27728	Pass
27729	Pass	27730	Pass	27731	Pass	27732	Pass
27733	Pass	27734	Pass	27735	Pass	27736	Pass
27737	Pass	27738	Pass	27739	Pass	27740	Pass
27741	Pass	27742	Pass	27743	Pass	27744	Pass
27745	Pass	27746	Pass	27747	Pass	27748	Pass
27749	Pass	27750	Pass	27751	Pass	27752	Pass
27753	Pass	27754	Pass	27755	Pass	27756	Pass
27757	Pass	27758	Pass	27759	Pass	27760	Pass
27761	Pass	27762	Pass	27763	Pass	27764	Pass
27765	Pass	27766	Pass	27767	Pass	27768	Pass
27769	Pass	27770	Pass	27771	Pass	27772	Pass
27773	Pass	27774	Pass	27775	Pass	27776	Pass
27777	Pass	27778	Pass	27779	Pass	27780	Pass
27781	Pass	27782	Pass	27783	Pass	27784	Pass
27785	Pass	27786	Pass	27787	Pass	27788	Pass
27789	Pass	27790	Pass	27791	Pass	27792	Pass
27793	Pass	27794	Pass	27795	Pass	27796	Pass
27797	Pass	27798	Pass	27799	Pass	27800	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory