

HYDRO PRESSURE TEST

TC No.: HPT/A4/A50/RQ/082/25	Model No.: KFARQ-4-50%	Date: 06-11-2025
Type and Capacity of Extinguisher	: KFARQ-4-50%-Kanex ABC Dry Powder Fire Extinguisher Cap. 4 Kg.	
Batch Number	: KFARQ50%4 082/25	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 08101 To 8200 And 8105A	
Month of Manufacturing	: Nov/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 8105A and removed from the Lot/Batch							
8101	Pass	8102	Pass	8103	Pass	8104	Pass
8105	Pass	8106	Pass	8107	Pass	8108	Pass
8109	Pass	8110	Pass	8111	Pass	8112	Pass
8113	Pass	8114	Pass	8115	Pass	8116	Pass
8117	Pass	8118	Pass	8119	Pass	8120	Pass
8121	Pass	8122	Pass	8123	Pass	8124	Pass
8125	Pass	8126	Pass	8127	Pass	8128	Pass
8129	Pass	8130	Pass	8131	Pass	8132	Pass
8133	Pass	8134	Pass	8135	Pass	8136	Pass
8137	Pass	8138	Pass	8139	Pass	8140	Pass
8141	Pass	8142	Pass	8143	Pass	8144	Pass
8145	Pass	8146	Pass	8147	Pass	8148	Pass
8149	Pass	8150	Pass	8151	Pass	8152	Pass
8153	Pass	8154	Pass	8155	Pass	8156	Pass
8157	Pass	8158	Pass	8159	Pass	8160	Pass
8161	Pass	8162	Pass	8163	Pass	8164	Pass
8165	Pass	8166	Pass	8167	Pass	8168	Pass
8169	Pass	8170	Pass	8171	Pass	8172	Pass
8173	Pass	8174	Pass	8175	Pass	8176	Pass
8177	Pass	8178	Pass	8179	Pass	8180	Pass
8181	Pass	8182	Pass	8183	Pass	8184	Pass
8185	Pass	8186	Pass	8187	Pass	8188	Pass
8189	Pass	8190	Pass	8191	Pass	8192	Pass
8193	Pass	8194	Pass	8195	Pass	8196	Pass
8197	Pass	8198	Pass	8199	Pass	8200	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory