

HYDRO PRESSURE TEST

TC No.: HPT/F45/RQ/052/25	Model No.: KFMRQ-45	Date: 25-11-2025
Type and Capacity of Extinguisher	: KFMRQ-45-Kanex M Foam Trolley Mounted Fire Extinguisher Cap. 45 Ltr.	
Batch Number	: KFMRQ45 052/25	
Batch Quantity	: 50.00 Nos.	
Serial Numbers	: 02551 To 2600	
Month of Manufacturing	: Nov/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on Cylinder Sr.No.2505A and which is removed from the batch (51st batch)							
2551	Pass	2552	Pass	2553	Pass	2554	Pass
2555	Pass	2556	Pass	2557	Pass	2558	Pass
2559	Pass	2560	Pass	2561	Pass	2562	Pass
2563	Pass	2564	Pass	2565	Pass	2566	Pass
2567	Pass	2568	Pass	2569	Pass	2570	Pass
2571	Pass	2572	Pass	2573	Pass	2574	Pass
2575	Pass	2576	Pass	2577	Pass	2578	Pass
2579	Pass	2580	Pass	2581	Pass	2582	Pass
2583	Pass	2584	Pass	2585	Pass	2586	Pass
2587	Pass	2588	Pass	2589	Pass	2590	Pass
2591	Pass	2592	Pass	2593	Pass	2594	Pass
2595	Pass	2596	Pass	2597	Pass	2598	Pass
2599	Pass	2600	Pass				

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 Minute and found satisfactory. No any leakage observed.



Authorized Signatory