



UQGS2.S36611 - Heat-automatic Fire Detectors - Component

Heat-automatic Fire Detectors - Component

Kanadia Fyr Fyter Pvt.Ltd

S36611

Plot No. 7/8, Paras Industrial Estate, Nr. Garibsha Pir, Sihor
Bhavnagar, Gujarat 364240 India

Heat Detection Tubing Model(s) KANEX, rated 280.4 F (138 C) @ 15 Bar

Marking: Company name and model designation.

Last Updated on 2022-05-31

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under UL's Follow-Up Service. Only those products bearing the UL Mark should be considered to be Certified and covered under UL's Follow-Up Service. Always look for the Mark on the product.

UL permits the reproduction of the material contained in the Online Certification Directory subject to the following conditions: 1. The Guide Information, Assemblies, Constructions, Designs, Systems, and/or Certifications (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from the Online Certifications Directory with permission from UL" must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "© 2022 UL LLC"