

# HYDRO PRESSURE TEST

|                                   |                                                                 |                  |
|-----------------------------------|-----------------------------------------------------------------|------------------|
| TC No.: HPT/A6/A50/RQ/338/25      | Model No.: KFARQ-6-50%                                          | Date: 25-11-2025 |
| Type and Capacity of Extinguisher | : KFARQ-6-50%-Kanex ABC Dry Powder Fire Extinguisher Cap. 6 Kg. |                  |
| Batch Number                      | : KFARQ50%6 338/25                                              |                  |
| Batch Quantity                    | : 101.00 Nos.                                                   |                  |
| Serial Numbers                    | : 33701 To 33800 And 33705A                                     |                  |
| Month of Manufacturing            | : Nov/25                                                        |                  |

| Sr. Nos.                                                      | Result | Sr. Nos. | Result | Sr. Nos. | Result | Sr. Nos. | Result |
|---------------------------------------------------------------|--------|----------|--------|----------|--------|----------|--------|
| Burst test conducted on 33705A and removed from the Lot/Batch |        |          |        |          |        |          |        |
| 33701                                                         | Pass   | 33702    | Pass   | 33703    | Pass   | 33704    | Pass   |
| 33705                                                         | Pass   | 33706    | Pass   | 33707    | Pass   | 33708    | Pass   |
| 33709                                                         | Pass   | 33710    | Pass   | 33711    | Pass   | 33712    | Pass   |
| 33713                                                         | Pass   | 33714    | Pass   | 33715    | Pass   | 33716    | Pass   |
| 33717                                                         | Pass   | 33718    | Pass   | 33719    | Pass   | 33720    | Pass   |
| 33721                                                         | Pass   | 33722    | Pass   | 33723    | Pass   | 33724    | Pass   |
| 33725                                                         | Pass   | 33726    | Pass   | 33727    | Pass   | 33728    | Pass   |
| 33729                                                         | Pass   | 33730    | Pass   | 33731    | Pass   | 33732    | Pass   |
| 33733                                                         | Pass   | 33734    | Pass   | 33735    | Pass   | 33736    | Pass   |
| 33737                                                         | Pass   | 33738    | Pass   | 33739    | Pass   | 33740    | Pass   |
| 33741                                                         | Pass   | 33742    | Pass   | 33743    | Pass   | 33744    | Pass   |
| 33745                                                         | Pass   | 33746    | Pass   | 33747    | Pass   | 33748    | Pass   |
| 33749                                                         | Pass   | 33750    | Pass   | 33751    | Pass   | 33752    | Pass   |
| 33753                                                         | Pass   | 33754    | Pass   | 33755    | Pass   | 33756    | Pass   |
| 33757                                                         | Pass   | 33758    | Pass   | 33759    | Pass   | 33760    | Pass   |
| 33761                                                         | Pass   | 33762    | Pass   | 33763    | Pass   | 33764    | Pass   |
| 33765                                                         | Pass   | 33766    | Pass   | 33767    | Pass   | 33768    | Pass   |
| 33769                                                         | Pass   | 33770    | Pass   | 33771    | Pass   | 33772    | Pass   |
| 33773                                                         | Pass   | 33774    | Pass   | 33775    | Pass   | 33776    | Pass   |
| 33777                                                         | Pass   | 33778    | Pass   | 33779    | Pass   | 33780    | Pass   |
| 33781                                                         | Pass   | 33782    | Pass   | 33783    | Pass   | 33784    | Pass   |
| 33785                                                         | Pass   | 33786    | Pass   | 33787    | Pass   | 33788    | Pass   |
| 33789                                                         | Pass   | 33790    | Pass   | 33791    | Pass   | 33792    | Pass   |
| 33793                                                         | Pass   | 33794    | Pass   | 33795    | Pass   | 33796    | Pass   |
| 33797                                                         | Pass   | 33798    | Pass   | 33799    | Pass   | 33800    | Pass   |

**Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.**



**Authorized Signatory**