

HYDRO PRESSURE TEST

TC No.: HPT/A6/A50/RQ/340/25	Model No.: KFARQ-6-50%	Date: 01-12-2025
Type and Capacity of Extinguisher	: KFARQ-6-50%-Kanex ABC Dry Powder Fire Extinguisher Cap. 6 Kg.	
Batch Number	: KFARQ50%6 340/25	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 33901 To 34000 And 33905A	
Month of Manufacturing	: Dec/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 33905A and removed from the Lot/Batch							
33901	Pass	33902	Pass	33903	Pass	33904	Pass
33905	Pass	33906	Pass	33907	Pass	33908	Pass
33909	Pass	33910	Pass	33911	Pass	33912	Pass
33913	Pass	33914	Pass	33915	Pass	33916	Pass
33917	Pass	33918	Pass	33919	Pass	33920	Pass
33921	Pass	33922	Pass	33923	Pass	33924	Pass
33925	Pass	33926	Pass	33927	Pass	33928	Pass
33929	Pass	33930	Pass	33931	Pass	33932	Pass
33933	Pass	33934	Pass	33935	Pass	33936	Pass
33937	Pass	33938	Pass	33939	Pass	33940	Pass
33941	Pass	33942	Pass	33943	Pass	33944	Pass
33945	Pass	33946	Pass	33947	Pass	33948	Pass
33949	Pass	33950	Pass	33951	Pass	33952	Pass
33953	Pass	33954	Pass	33955	Pass	33956	Pass
33957	Pass	33958	Pass	33959	Pass	33960	Pass
33961	Pass	33962	Pass	33963	Pass	33964	Pass
33965	Pass	33966	Pass	33967	Pass	33968	Pass
33969	Pass	33970	Pass	33971	Pass	33972	Pass
33973	Pass	33974	Pass	33975	Pass	33976	Pass
33977	Pass	33978	Pass	33979	Pass	33980	Pass
33981	Pass	33982	Pass	33983	Pass	33984	Pass
33985	Pass	33986	Pass	33987	Pass	33988	Pass
33989	Pass	33990	Pass	33991	Pass	33992	Pass
33993	Pass	33994	Pass	33995	Pass	33996	Pass
33997	Pass	33998	Pass	33999	Pass	34000	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory